



## **NFPA 72 CERTIFICATE REQUIREMENTS** (2020 MSFC and NFPA 72)

**Code Reference – MSFC 907.6.6 Monitoring** (Amended by Shakopee Ordinance)

**[Shakopee] 907.6.6.3 System certification.** All required Fire Alarm Systems installed after January 1, 2002 shall be monitored by an approved central station and shall have a Certification Certificate as required by NFPA 72, Chapter 26. All existing required Fire Alarm Systems where 50% or more of the system devices are updated or modified or the main fire alarm control panel is replaced shall have a Certification Certificate as required by NFPA 72, Chapter 26 issued certifying that the fire alarm system follows adopted codes. Certification Certificates shall be issued by an organization approved by the *fire code official*.

### **General Requirements**

All fire alarm systems and sprinkler monitoring systems installed after January 1, 2004 shall be provided with an Indication of Central Station Service as required by NFPA 72 (2010) Section 26.3.4. The following information shall be provided on the Certificate.

Authority Having Jurisdiction: SHAKOPEE FIRE DEPARTMENT

Responding Fire Department: SHAKOPEE FIRE DEPARTMENT

System Deviations:

ANNUAL TESTING OF SYSTEM PER AHJ

RUNNER SERVICE NOT PROVIDED FOR FIRE DEPARTMENT KEYBOX TAMPERS

Date: 04/01/2020

Page 1/1

NFPA 72 Certificate Requirements.doc